

Emission Test Certificate

Tuesday June 2nd, 2020

Supplier: Alpine MDF Industries Pty Ltd (99 Crosher Lane, Wangaratta, VIC, 3677, Australia)

Sample Description: MDF produced with MDI Resin panel

Date Tested: May 2020 (Tested through FORAY Laboratories - NATA Accreditation 1231)


Test Method: ASTM D5116-17 "Standard Guide for Small-Scale Environmental Chamber Determinations of Organic Emissions from Indoor Materials/Products".

Emission Data (24 hrs exposure):

<p>Green Building Council of Australia Green Star Design & As Built v1.3 13.1.2B & 13.2 Green Star Interiors V1.3 - 12.1.2B</p>	<p>MDF produced with MDI Resin</p>
<p>Total Volatile Organic Compound Emission Rate limit: ≤0.500 mg/m²/hr</p>	<p>Total Volatile Organic Compound Emission Rate: 0.022 mg/m²/hr</p>
<p>Formaldehyde Emission limit for Super E0 classification (EN-717-1): ≤ 0.04 mg/m³</p>	<p>Formaldehyde concentration in air in the emission chamber: 0.017 mg/m³</p>
<p>Formaldehyde Emission Class Super E0: Pass</p>	



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Travis Hale
BSc (Biotechnology)
Consultant



Tuan Duong
B Eng. (Chem.)
Consultant

V2005018R01A