

09/07/2019

## Vapour Control Classification



### 4mm F22 Plywood Bracing

This is to certify that Gbrace 4mm F22 Plywood Bracing has been independently tested by a NATA accredited testing authority and in accordance with the requirements of AS/NZS 4200.1:2017 Pliable building membranes and underlays Part 1: Materials, the vapour control classification has been determined in accordance with ASTM E96, Procedure B (wet-cup test).

Mean Vapour Permeance: 0.6275  $\mu\text{g}/\text{N.s}$ 

AWTA Product Testing

Test Number : 19-003457

Issue Date : 03/07/2019

VAPOUR CONTROL MEMBRANE (VCM) CLASSIFICATION			
Class 3	Vapour permeable	$\geq 0.1429 \mu\text{g}/\text{N.s}$	$< 1.1403 \mu\text{g}/\text{N.s}$



Andrew Powell

**APPROVED SIGNATORY**

Gunnensen Pty Ltd ABN 35 004 051 003